

FORD ANALYTICAL LABORATORIES

CHEMICAL AND BACTERIOLOGICAL ANALYSIS

DATE: 01/14/94
CERTIFICATE OF ANALYSIS

*FREEZE CREEK WATER
* THE BOYER CO.
127 SO. 500 E. #127
SLC, UT 84102

94-010280

SAMPLE: DRINKING WATER SAMPLES COLLECTED AND RECEIVED 1-4-94
FOR LEAD/COPPER ANALYSIS; SYSTEM #18143.

LOT 30 7:00	LOT 36 6:00	LOT 47 7:00	METHOD DETECTION LIMIT
----------------	----------------	----------------	------------------------------

Copper Cu mg/l EPA 220.1	.65	.12	.18	.03
Lead Pb mg/l EPA 239.2	ND	ND	ND	.003
Temp. deg C at Receipt	22	22	22	
pH at Receipt	7	7	7	

*SAMPLES FIXED UPON RECEIPT

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.