

CHEMICAL AND BACTERIOLOGICAL ANALYSIS

# FORD ANALYTICAL LABORATORIES

## CERTIFICATE OF ANALYSIS

DATE: 06/15/94

CC: STATE HEALTH DEPT.

94-051900

\*FREEZE CREEK WATER  
& THE BOYER CO.  
127 SO. 500 E. #127  
SLC, UT 84102

SAMPLE: DRINKING WATER SAMPLES FROM EMIGRATION OAKS COLLECTED  
6-3-94 RECEIVED 6-3-94 FOR LEAD/COPPER ANALYSIS,  
SYSTEM #18163.

SEYBOLDT  
LOT 6  
7:30 AM

JIM ELDER  
LOT 22  
5455 E.  
PIONEER  
4:30 AM

LOT 8  
7:30 AM

METHOD  
DETECTION  
LIMIT

Copper Cu mg/l EPA 200.7

.227

.499

.616

.010

Lead Pb mg/l EPA 200.9

ND

ND

ND

.005

\*SAMPLES FIXED UPON RECEIPT

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.