



State of Utah

Department of
Environmental Quality

Richard W. Sprott
Executive Director

DIVISION OF DRINKING WATER
Kenneth H. Bousfield, P.E.
Director

JON M. HUNTSMAN, JR.
Governor

GARY HERBERT
Lieutenant Governor

June 3, 2008

Fred Smolka
Emigration Imp District
P.O. Box 58945
Salt Lake City, Utah 84158

Dear Mr. Smolka:

Subject: Water System Violation – Water System #UTAH18143

Our records indicate your water system is in violation of the State of Utah Public Drinking Water Rules as follows:

You did not submit your 2008 1st quarter report for the Disinfectants/Disinfection Byproducts Rule. As a result, the following violations apply:

R309-210-8(3)(a)

You did not take the required number of chlorine samples in your distribution system for January, February or March 2008. A minimum of three samples per week is required. This is a Tier 3 violation.

R309-210-8(3)(a)

You did not take chlorine samples with your Total Coliform Sample(s) for January, February or March 2008. This is a Tier 3 violation.

R309-210-8(3)(a)

You did not take the required number of chlorinator readings at your chlorinator(s) for January, February or March 2008. A minimum of three readings per week per chlorinator is required. This is a Tier 3 violation.

Tier 3 Public Notice:

Because your system has violated these monitoring requirements, you must notify all consumers within 1 year after you learn of the violation (R309-220-7(2)) or you may choose to include the notification in your annual Consumer Confidence Report. This public notice requirement cannot

Fred Smolka
Page 2
June 3, 2008

be waived once a violation has occurred. A copy of the notice you send to each consumer must be forwarded to us within 10 days after issuing the notice (R309-105-16(2)). Attached is a sample public notice for your use.

If this letter is in error, and you do have the missing item(s), please send them to Brad Holdaway at our office. You can e-mail your report to ddwreports@utah.gov, e-mail them to (801) 536-4211 or mail them to P.O. Box 144830, Salt Lake City, Utah 84114. Upon receipt, we can delete this violation from your record.

If you have any questions regarding this matter, please call Brad Holdaway at (801) 536-0063. Please reference your water system number in all correspondence.


Sincerely,



Patti Fauver
Rules Program Manager

BH:jsy

Enclosure



cc: Salt Lake Valley Health Department