

# 2015 Sanitary Survey Completed by Lili Benavides, Salt Lake County Health Department

Question Number

- |       |  |   |
|-------|--|---|
| 10    | Are full and empty cylinders of chlorine gas stored in areas that are not in direct sunlight or exposed to excessive heat?   | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 11    | Is a weight scale provided for weighing chlorine gas cylinders / containers?   | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 12    | Is respiratory protection equipment, available where chlorine gas is handled, and is it stored at a convenient location, but not inside any room where chlorine is stored? | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 13    | <b>Is the chlorine cylinder utilized 150 pounds in capacity?</b>   | <input type="checkbox"/> Yes<br><input checked="" type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown |
| 13.01 | Is a type "A" leak repair kit approved by the Chlorine Institute available?  | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 13.02 | Is a bottle of ammonium hydroxide (56 per cent ammonia solution) available for chlorine leak detection?  | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 14    | <b>Is the chlorine cylinder utilized 1 ton in capacity?</b>  | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 14.01 | Is a type "B" leak repair kit approved by the Chlorine Institute available?  | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 14.02 | Is a means of leak detection provided?   | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |
| 14.03 | Does the water supply to each injector have a separate shut-off valve?   | <input type="checkbox"/> Yes<br><input type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown            |

**TP002-WELL 2 CHLORINATOR - (Active) / General**

**General:**

- |      |  |   |
|------|--|---|
| 1    | Is this plant operated on seasonal basis?  | <input type="checkbox"/> Yes<br><input checked="" type="checkbox"/> No<br><input type="checkbox"/> NA<br><input type="checkbox"/> Unknown |
|      | Notes: At the time of the survey, this chlorinator was active on the inventory list provided to the Health Department by DDW. On July 31, the Health Department was notified by DDW that this may be an unapproved facility. |   |
| 1.01 | Numeric month of beginning operation   |   |