



Date: 3/19/97

To: Freeze Creek Water Company  
 The Boyer Company attn: Dick Moffat  
 127 South 500 East, Suite #100  
 Salt Lake City, UT 84102

Group #: 13738  
 Lab #: 97-U002007  
 System #: #18143

Sample Desc: Well #1

(Boyer Well Nr. 1)

Date Sampled: 2/24/97  
 Date Submitted: 2/24/97

Time Sampled: 15:30  
 Time Received: 16:20

## CERTIFICATE OF ANALYSIS

PARAMETER	RESULT	MDL	DATE ANALYZED	METHOD	ANALYST
INORGANIC PARAMETERS					
Cyanide (T), mg/L	< 0.002	0.002	3/ 4/97 8:00	ASTM D2036	TH
Fluoride, mg/L	0.3	0.1	3/ 7/97 13:00	EPA 340.2	EG
Mercury (T), as Hg, mg/L	< 0.0002	0.0002	3/ 4/97 14:00	EPA 245.1	BJP
Sulfate, mg/L	88	33	3/18/97 9:00	EPA 375.4	TM
Total Dissolved Solids, mg/L	564	5	2/26/97 14:30	EPA 160.1	LS
Turbidity, NTU	2.25	0.05	2/24/97 16:45	EPA 180.1	LS
Barium (T), as Ba, mg/L	0.07	0.01	2/25/97 11:08	EPA 200.7	LH
Beryllium (T), as Be, mg/L	< 0.001	0.001	2/25/97 11:08	EPA 200.7	LH
Chromium(T), as Cr, mg/L	< 0.005	0.005	2/25/97 11:08	EPA 200.7	LH
Copper (T), as Cu, mg/L	< 0.01	0.01	2/26/97 12:09	EPA 200.7	LH
Nickel (T), as Ni, mg/L	< 0.01	0.01	2/26/97 12:09	EPA 200.7	LH
Sodium (T), as Na, mg/L	71.4	0.1	2/26/97 12:09	EPA 200.7	LH
Antimony (T), as Sb, mg/L	< 0.002	0.002	3/ 3/97 10:53	EPA 200.9	EG
Arsenic (T), as As, mg/L	< 0.005	0.005	2/28/97 10:21	EPA 200.9	EG
Cadmium (T), as Cd, mg/L	< 0.001	0.001	2/28/97 12:47	EPA 200.9	EG
Lead (T), as Pb, mg/L	< 0.005	0.005	2/26/97 9:52	EPA 200.9	EG
Selenium (T), as Se, mg/L	0.004	0.002	2/27/97 15:58	EPA 200.9	EG
Thallium (T), as Tl, mg/L	< 0.001	0.001	3/ 3/97 13:54	EPA 200.9	EG
Receiving Temperature, C	10.5		2/24/97 16:20		RCG

Approved By: \_\_\_\_\_

{generic.rpt}

DIVISION OF DRINKING WATER

6100 SOUTH STRATLER  
 SALT LAKE CITY UTAH 84107 6905  
 801 262 7299 PHONE  
 801 262 7378 FAX