



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY HERBERT  
Lieutenant Governor

Department of  
Environmental Quality

William J. Sinclair  
Acting Executive Director

DIVISION OF DRINKING WATER  
Kenneth H. Bousfield, P.E.  
Director

December 15, 2008

Fred Smolka  
Emigration ID  
PO Box 58945  
Salt Lake City, Utah 84158

Dear Mr. Smolka:

Subject: Notice of Violation – Water System #UTAH18143

Our records indicate your water system is in violation of the State of Utah Public Drinking Water Rules as follows:

As a community water system that chlorinates you did not submit chlorination reports. This is a required part of the Stage 2 DBP (disinfection byproducts) Rule and consequently any IDSE (initial distribution system evaluation) waivers will not apply. This results in your system being required to complete IDSE samples as part of the Stage 2 Disinfectants/Disinfection Byproducts Rule. The following violations apply:

You did not take the required number of chlorinator readings at your chlorinator(s) for 2<sup>nd</sup> and 3<sup>rd</sup> quarter 2008 or submit any quarterly reports. A minimum of three readings per week per chlorinator is required. This is a Tier 3 violation.

Failure to comply with water quality monitoring requirements is a violation of Section 309-210 of the rules.

Because your system has violated these monitoring requirements, you must notify all consumers within 1 year after you learn of the violation (R309-220-7(2)). You may choose to include the notification in your annual Consumer Confidence Report. This public notice requirement cannot be waived once a violation has occurred. A copy of this notice must be forwarded to the Division of Drinking Water within 10 days after issuing the notice (R309-105-16(2)). Attached is a sample public notice for your use.

In addition, you now must complete Standard Monitoring for disinfection byproducts. This involves collecting DBP samples for a total of 4 quarters. A standard monitoring sampling form

Fred Smolka  
Page 2  
December 15, 2008

must be submitted. This sampling needs to be completed by March 1, 2010 as per the Stage 2 Disinfection Byproducts Rule.

If this letter is in error, and you do have the missing item(s), please contact Brad Holdaway at our office. Upon receipt of the missing items we can delete this violation from your record.

If you have any questions regarding this matter, please call Brad Holdaway at (801) 536-0063. Please reference your water system number in all correspondence.

Sincerely,

A handwritten signature in cursive script that reads "Patti J. Fauver". The signature is written in black ink and is positioned above the printed name and title.

Patti J. Fauver  
Program Manager

PJF:bh

Enclosure

cc: Local Health Department