## 5. Storage Reservoir

5.C Access covers to the reservoir must include a functional gasket which excludes dust and insects.

60 days 10 points

## 6. Distribution System

6.D The system does not have storage capacity to meet calculated peak daily demand. Please check with the Division of Drinking Water for further details. 18 months 7 points

## SUMMARY

	REQUIREMENT	TO BE FIXED BY	. ]	POINTS
1.D	Bacteria sampling site pla	n 7-15-00	5	points
	lead/copper plan	7-15-00	10	points
1.G	Cross connect public ed	8-30-00	10	points
	Trained cross connect op	8-30-00	10	points
	Hazard assessment record	8-30-00	10	points
1.J	Cross connect enforcement	8-30-00	10	points
2.E	Well discharge piping	6-30-00	1	point
5.C	Reservoir access	7-30-00	10	points
6.D	Storage capacity	12-01-01	7	points

## Total Points 73

The new water system rating criteria rule, often called the Improvement Priority System (IPS), is in effect for this survey. The points from this survey will be added to your total system points on the "to be fixed by" date. Otherwise they shall be given at the time the state receives this survey. If the system has corrected deficiencies and has notified the state before those dates, those points will not be added.

Under the Improvement Priority System (IPS) community water systems are rated "Not Approved" when the point total equals or exceeds 150 points. Similarly, a "Not Approved" rating is assigned when points equal or exceeds 120 points for Non-Transient Non-Community water systems, and equals or exceeds 100 points for Non-Community water systems.