

Sanitary Survey - Survey Responses

PWS Number: UTAH18143

Survey ID: 66

Survey Date: 8/13/2015

Survey Name: EMIGRATION ID 2015 NEW

User Name: John Oakeson

Question Number

DS001-UTAH18143 DISTRIBUTION SYSTEM - (Active) / Design

- 1 Do all water mains (installed after 1995) that provide fire flow have a diameter of at least 8 inches? (If no new lines have been added after 1995 answer "yes")
- Yes
 No
 NA
 Unknown
- 2 Is there any asbestos/cement pipe in use in the system?
- Yes
 No
 NA
 Unknown
- 2.1 When was last asbestos analysis performed?

