

Handwritten Notes of Dr. Steve Onysko, Utah Division of Drinking Water ("DDW") to Lili Benavides, Salt Lake County Health Department

Question Number

- 7.02 Pump discharge piping: a positive-acting check valve between the sample tap and the isolation valve? Yes
 No
 NA
 Unknown
- 7.03 Pump discharge piping: pressure gauge? Yes
 No
 NA
 Unknown
- 7.04 Pump discharge piping: a means of measuring flow? Yes
 No
 NA
 Unknown
- 7.05 Pump discharge piping shut off valve? Yes
 No
 NA
 Unknown
- 8 **If the well pumps directly into a distribution system, is there a means to release trapped air from the pump discharge piping? (for example, pumps directly to a tank,, has an air release valve or pump to waste line) answer "yes" explain in notes (Answer 9.01, 9.02, 9.03 for air release valve only)** Yes
 No
 NA
 Unknown
- 8.01 For a well with an air vacuum relief valve on the well discharge piping, is the discharge piping downturned? Yes
 No
 NA
 Unknown
- 8.02 For a well with an air vacuum relief valve on the well discharge piping, is the discharge screened with a #14 mesh screen? Yes
 No
 NA
 Unknown
- 8.03 For a well with an air vacuum relief valve on the well discharge piping, is the discharge piping have a 6 inch clearance to prevent contamination from entering the the piping? Yes
 No
 NA
 Unknown
- 9 Are the correct types of lubricant used (ANSI/NSF 60)? Yes
 No
 NA
 Unknown
Notes: The pump is submersible, not lubricant is required
- 10 Is rotating and electrical equipment provided with protective guards? Yes
 No
 NA
 Unknown

Sources / Groundwater

WS002-WELL #2 - (Active) / General:

- 1 Is this a seasonal source? Yes
 No
 NA
 Unknown
- 1.02 Numeric month of beginning operation: Yes
 No
 NA
 Unknown

cannot find WS002 approval; DDW 9-20-95 letter to EID lists reasons WS002 cannot be approved; 1996 survey report also notes lack of WS002 approval;