



Utah!

Where ideas connect

Department of Environmental Quality
Division of Drinking Water

Michael O. Leavitt
Governor
Dianne R. Nielson, Ph.D.
Executive Director
Kevin W. Brown, P.E.
Director

150 North 1950 West
P.O. Box 144830
Salt Lake City, Utah 84114-4830
(801) 536-4200
(801) 536-4211 Fax
(801) 536-4414 T.D.D.
drinkingwater.utah.gov

Drinking Water Board

Dale F. Pierson
Chairman
Anne Erickson, Ed.D.
Vice Chairman
Myron Bateman
Jay W. Franson, P.E.
Laurie McNeill, Ph.D.
Nancy Melich
Dianne R. Nielson, Ph.D.
Charlie Roberts
Petra Rust
Ronald Thompson
Chris Webb

October 30, 2003

Fred Smolka
Emigration Improvement District
P.O. Box 58945
Salt Lake City, Utah 84158

Dear Mr. Smolka:

Subject: Temporary Operating Permit, Water System #18143, File #05952, 1 MG Water Tank

The file for this project has been reviewed by Division engineers, who have ascertained that the subject temporary operating permit can be issued to Emigration Improvement District. This action applies only to the specific project referenced above. This issuance is based upon the information contained in the file including a certification of proper tank disinfection from the engineer, Ron Rash, and acceptable results from two bacteriological water analyses.

The information you have submitted indicates that all conditions of temporary operating permit issuance were accomplished. **This letter is your Temporary Operating Permit that allows you to use the new water tank in your drinking water system until February 1, 2004.** At such time, you must present the Division with proof of compliance with all requirements for a permanent Operating Permit. **This shall include proof that the construction defects responsible for substantial leakage from the tank at the time of issuance of this Temporary Operating Permit have been corrected.** If you have any questions, please call Steve Onysko, of my staff at, (801) 536-0096.

Sincerely,

DRINKING WATER BOARD

Kevin W. Brown, P.E.
Executive Secretary

SJO

cc: Royal DeLegge, Salt Lake Valley Health Dept., 2001 South State, #S-2500, Salt Lake City, UT 84190-2150
Ron Rash, Carollo Engineers, 1265 East Fort Union Blvd., Suite 200, Salt Lake City, UT 84047

U:\Dr_Water\Engineer\Sonysko\plans\05952c.doc