EID Trustee Meeting – September 13, 2018

EID Trustee Chairman Hughes: "Maintenance Report Brigham Fork Well."

EID Manager Eric Hawkes: "We pulled a number of samples for iron bacteria... and we pulled a water quality sample... [it was] above the threshold of the [Utah State] Division of Drinking Water for sulfate and turbidity."

EID Trustee Chairman Hughes: "Does it smell like sulfur?"

EID Manager Eric Hawkes: "If you remember when we turned it off three years ago there were complaints about sulfur – a sulfur smell."