

UTAH DIVISION OF DRINKING WATER

PUBLIC WATER SYSTEM IMPROVEMENT PRIORITY REPORT
05/01/03

18143 - EMIGRATION IMP DISTRICT

System Manager: FRED SMOLKA
System Address: PO BOX 58945
SALT LAKE UT 84158
Phone Number.: 582-6176
Type of System: COMMUNITY-PRIVATELY OWNED

Searches Back to...: 02/20
Current Rating.....: Approved
Period of Operation: 01/01 to 12/31
Last Surveyed By...: OAKESON/WI
Date Last Surveyed.: 04/30/03

General/Administration Information

SYSTEM HAS WRITTEN EMERGENCY RESPONSE PLAN 10 CREDIT POINTS Credit 20 points
SYSTEM HAS WRITTEN FINANCIAL PLAN 10 CREDIT POINTS

Certified Operator Information

This system has Operators that are certified at a higher level than required Credit 10 points

Bacteriological Information

No Bacteriological Violations found

Chemical Information

MCL exceedance for TURBIDITY on 08/29/00 for source 01 (WELL #1) 30 points

Lead / Copper Information

No Lead / Copper Infractions

Physical Facilities Information

WELL #1 MUST HAVE SMOOTH NOSED SAMPLE TAP 1 Pts Effective 05/30/03
REPAIR KIT FOR 150 POUND CL2 CYLINDER 2 IPS POINTS 7 Pts Effective 05/30/03
SCBA FOR CHLORINE FACILITY 5 IPS POINTS
SCREEN ON DRAIN LINE OF 300,000 GALLON RESERVOIR NEEDS REPAIR 2 Pts Effective 05/30/03

Total Points 0 points

****RETURN THIS REPORT WITH CORRECTIONS****