



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF DRINKING WATER
Kenneth H. Bousfield, P.E.
Director

March 5, 2013

FRED SMOLKA
EMIGRATION IMPROVEMENT DISTRICT
PO BOX 58945
SALT LAKE CITY, UT 84158

Dear Mr. SMOLKA:

Subject: Water System Violation – Water System #UTAH18143

Our records show your water system is in violation of the State of Utah Public Drinking Water Rules as follows:

For the month of January, no ROUTINE bacteriologic analysis results were reported to our office. You are required to collect at least one sample per month, have it analyzed, and send the results to us. Failure to collect samples is a violation of Section R309-210-5(1) of the rules. This violation results in the addition of 35 points to your system's Improvement Priority System Report (IPS) and could adversely effect your water system's rating (R309-400).

You must notify all consumers within one year after you learn of the violation (R309-220-7). Failure to provide public notification will result in the addition of five points to your system's IPS report. A copy of the notice you send to each customer must be forwarded to us within ten days after issuing the notice. Refer to the enclosed example of a public notice.

If you have any questions concerning this letter, please contact Janet Lee at (801) 536-0088. Please reference your water system number in all correspondence.

If this letter is in error, and you do have ROUTINE bacteriological analysis results for this month, please send a copy(ies). Upon receipt of the results we can delete this violation from your record.

Sincerely,

Patti J. Fauver
Rules Program Manager

PF:jl

Enclosure

CC: Salt Lake Valley Health Department