

(2015 Sanitary Survey Completed By Lili Benavidez, Salt Lake County Health Department)

Question Number

- | | | |
|------|--|---|
| 7.01 | Pump discharge piping: a smooth-nosed sampling tap? | <input type="checkbox"/> Yes
<input checked="" type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| | Notes: There is a tap but it is not smooth-nosed. | |
| 7.02 | Pump discharge piping: a positive-acting check valve between the sample tap and the isolation valve? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 7.03 | Pump discharge piping: pressure gauge? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 7.04 | Pump discharge piping: a means of measuring flow? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 7.05 | Pump discharge piping shut off valve? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 8 | If the well pumps directly into a distribution system, is there a means to release trapped air from the pump discharge piping? (for example, pumps directly to a tank,, has an air release valve or pump to waste line) answer "yes" explain in notes (Answer 9.01, 9.02, 9.03 for air release valve only) | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA

<input type="checkbox"/> Unknown |
| 8.01 | For a well with an air vacuum relief valve on the well discharge piping, is the discharge piping downturned? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 8.02 | For a well with an air vacuum relief valve on the well discharge piping, is the discharge screened with a #14 mesh screen? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| 8.03 | For a well with an air vacuum relief valve on the well discharge piping, is the discharge piping have a 6 inch clearance to prevent contamination from entering the the piping? | <input checked="" type="checkbox"/> Yes
<input type="checkbox"/> No
<input type="checkbox"/> NA

<input type="checkbox"/> Unknown |
| 9 | Are the correct types of lubricant used (ANSI/NSF 60)? | <input type="checkbox"/> Yes
<input type="checkbox"/> No
<input checked="" type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| | Notes: The pump is submersible, not lubricant is required | |
| 10 | Is rotating and electrical equipment provided with protective guards? | <input type="checkbox"/> Yes
<input type="checkbox"/> No
<input checked="" type="checkbox"/> NA
<input type="checkbox"/> Unknown |

Sources / Groundwater

WS002-WELL #2 - (Active) / General: Boyer Well Nr. 2

- | | | |
|---|---|---|
| 1 | Is this a seasonal source? | <input type="checkbox"/> Yes
<input checked="" type="checkbox"/> No
<input type="checkbox"/> NA
<input type="checkbox"/> Unknown |
| | Notes: During the time of the survey, this well was active on the inventory list provided by DDW. On July 31st, the health department was notified by DDW that this may be an unapproved source. | |