

Handwritten Notes of Dr. Steve Onysko, Utah Division of Drinking Water ("DDW") to Lili Benavides, Salt Lake County Health Department

Question Number

Storage / ST002-WILDFLOWER RESERVOIR - (Active)

Design:

- 1 What is the name of this storage facility? Wildflower Reservoir
- 2 What is the total capacity for this storage facility in gallons? (DO NOT USE COMAS IN NUMERIC ANSWER) 1000000
- Notes: The system manager states that the capacity of this tank is 1,000,000 gallons.
- 3 Is the area surrounding the ground-level storage structure graded in a manner that will prevent surface water from standing within 50 feet of it? Yes
 No
 NA
 Unknown
- 4 Does the storage tank roof cover show evidence of ponding with deterioration? Yes
 No
 NA
 Unknown

Operator says 1MG; DDW file# 05952, 8-11-02, 1MG preconstruction approval; DDW database shows 1.3 MG;

Storage / ST002-WILDFLOWER RESERVOIR - (Active)

Components:

- 1 Does the water storage tank have a safe access (such as ladders for tanks in excess of 20 feet, ladder guards, railings) or safely located entrance hatches? Yes
 No
 NA
 Unknown
- 2 Are air vents present? Yes
 No
 NA
 Unknown
- 2.01 Air Vents: Turned downward or covered from rain and dust? Yes
 No
 NA
 Unknown
- 2.02 Air Vents: Terminated at a minimum of 24 inches above the surface of a storage tank roof if the tank is a buried structure? Yes
 No
 NA
 Unknown
- 2.03 Air Vents: Screened with #14 non-corrodible mesh screen? Yes
 No
 NA
 Unknown
- 3 Are access openings present? Yes
 No
 NA
 Unknown
- 3.01 Access opening covers at least 4 inches above the tank roof surface or a minimum of 18 inches above any earthen cover? Yes
 No
 NA
 Unknown
- 3.02 Access openings: Is the access of the shoe box type with a minimum of a 2 inch overlap? Yes
 No
 NA
 Unknown